



# Declaration of Performance

According to Construction Products Regulation EU No. 305/2011

No. 1438-CPR-0754

1. Unique identification code of the product-type:

**SI SERIES P10i**  
**SI SERIES P10j**  
**SI SERIES P10i TR**  
**SI SERIES P10j TR**

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

**P10i**  
**P10j**  
**P10i TR**  
**P10j TR**

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

**Fire detection and Fire alarm systems – part 24: Components of Voice Alarm systems**  
**- Loudspeakers; EN 54-24:2008**

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

**Stamer Musikanlagen GmbH**  
**Magdeburger Straße 8**  
**66606 St. Wendel**  
**Germany**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

**Not applicable**

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

**System 1**

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:

**JEDNOSTKA NOTYFIKOWANA / NOTIFIED BODY 1438**  
**CENTRUM NAUKOWO-BADAWCZE OCHRONY PRZECIWPOŻAROWEJ**  
**im. Józefa Tuliszkowskiego**  
**PAŃSTWOWY INSTYTUT BADAWCZY**

performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the certificate of constancy of performance:

**1438-CPR-0754**

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

**Not applicable, see item 7**

9. Declared performance

Essential characteristics	Performance	Harmonised technical specification EN 54-24:2008; Clause
Frequency response limits	pass	4.2
Durability	pass	4.3
Construction	pass	4.4
Marking and data	pass	4.5
Reproducibility	pass	5.2
Rated impedance	pass	5.3
Horizontal and vertical coverage angles	pass	5.4
Maximum sound pressure level	pass	5.5
Rated noise power (durability)	pass	5.6
Dry heat (operational)	pass	5.7
Dry heat (endurance)	pass	5.8
Cold (operational)	pass	5.9
Damp heat, cyclic (operational)	pass	5.10
Damp heat, steady state (endurance)	pass	5.11
Damp heat, cyclic (endurance)	pass	5.12
Sulphur dioxide corrosion (endurance)	pass	5.13
Impact (operational)	pass	5.15
Vibration, sinusoidal (operational)	pass	5.16
Vibration, sinusoidal (endurance)	pass	5.17
Enclosure protection	pass	5.18

10. The performance of the product identified in point 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:




Lothar Stamer Dipl.Ing., Managing Director

St. Wendel, 4/22/2021



Stamer Musikanlagen GmbH  
Magdeburger Str. 8, 66606 St. Wendel  
Germany

 1438
Stamer Musikanlagen GmbH, Magdeburger Str. 8 66606 St. Wendel, Germany 21 1438-CPR-0754
EN 54-24 Loudspeaker for voice alarm systems in fire detection systems in buildings SI SERIES P10i • SI SERIES P10j SI SERIES P10i TR • SI SERIES P10j TR Provided options: Type B Technical data: See datasheet 2020-04 of the manufacturer